













Recirculating Filter Pumping System use Xerxes 22000 Gallon Tank (Above left)

on Tank (Above left)

ARTHUR R. OLSON & CO.

965 WESTSHORE DRIVE FOX LAKE, IL. 60020 (847) 651-1150 PROFESSIONAL ENGINEER

OF U.C. EXP. 11/09/2007



## FALCON CREST SUBDIVISION

LAKE VILLA, ILLINOIS

AX100 MEDIA FILTER & RECIRCULATION TANK DETAILS

| SHEET         |          |     |        |      |
|---------------|----------|-----|--------|------|
|               |          |     |        |      |
| 8             |          |     |        |      |
| 0             |          |     |        |      |
|               |          |     |        |      |
| of <b>11</b>  | LCHD     |     | A.R.O. | 9/15 |
| TE: 7/12/2006 | REVISION | NO. | BY     | ATE  |
|               |          |     |        |      |

## Note:

- One Orenco Advantex AX100 Media Filter has a loading rate of 2500 gal. per day with a peak loadiung rate of 5000 gal. per day.
- 2) For the system proposed the SIX Ax100 media filters have a combined loading rate of 15,000 gal per day with a max loading rate of 30,000 gal per day

  Output

  Description: